

## The State of Wyoming



## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

**ABANDONED MINES** (307) 332-5085

AIR QUALITY (307) 332-6755 (307) 332-3047

SOLID & HAZARDOUS WASTE (307) 332-6924

WATER QUALITY (307) 332-3144

## February 19, 2004

Dolly Potter, Environmental Engineer Solvay Minerals P.O. Box 1167 Green River, WY 82935

RE: Solvay Minerals Green River Soda Ash Plant

Stack Test Review

Dear Ms. Potter:

The Division has reviewed the stack test reports submitted by Solvay Minerals by letter dated January 27, 2004. The test reports were received by the Divison January 29, 2004. Evergreen Air Services Inc. was contracted by Solvay to conduct NOx emission tests on the "A" & "B" Calciners (Source ID#17). Sampling was conducted on November 18, 2003. Annual NOx emission tests are required by Operating Permit 30-126 condition F10(a). Methods 1-4 and 7E were utilized to determine NOx emissions.

A review of the test data indicates the "A" & "B" Calciners to be operating in compliance with the NOx emission limit set by Operating Permit 30-126. Operating Permit 30-126 limits NOx emissions from the calciner to 30.00 lb/hr. The test data shows the calciners tested at an average for three test runs at 23.8 lb/hr NOx, 79.3% of its allowable. The testing was performed at an average load of 75.9%. This percent load represents normal operation.

The Division will accept these tests as representative of NOx emissions at the time of testing from this source. A summary of the analysis is attached.

Please call me at 307-332-6755 if you have questions concerning this matter.

Sincerely,

Carl Disel

Air Quality Engineer

Cul R. Ding

Air Quality Division

2/19/2004

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION STACK TEST SUMMARY REPORT SOLVAY MINERALS GREEN RIVER SODA ASH PLANT (17) "A" AND "B" CALCINERS (EP1&2)

OBSERVED: [ ] TEST TYPE: Compliance Certification (Annual)		AVG: 23.8 24.2 ppmvd 192,627 75.9  ALLOW: 30 RATED CAPACITY: 400 TPH and 500 MMBtu/hr	%02: [12.2]
REVIEW DATE: 2/19/2004	NOX NOX PERCENT OF FULL LOAD ALLOWABLE 79.3 75.9	24.2 p	.4 scfm 192,630 %02: [12.2]
REVIEWER: Disel Review D/	TEST FIRM: EVEIGUE  TEST DATE  11/18/2003  STACK TEMP  291	341,940 SCFM @ 0%	

Annual compliance stack testing required by Operaing Permit 30-126 condition I utilized to determine NOx emissions. Three one hour test runs were performed.